



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



**Reporting: 112 of 4367 Rclds**

**Facility ID # Area 5 Pedestrian Signals**

**Author: Vaish, B**

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
1	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
2	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
3	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
4	Palos Verdes Dr. West & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
5	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
6	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rclds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
7	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
8	Palos Verdes Dr. West & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	7.1% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
9	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
10	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
11	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
12	Palos Verdes Dr. West & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	Stable floor surface is not provided.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
13	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
14	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
15	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
16	Palos Verdes Dr. West & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	5.9% slope.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



**Reporting: 112 of 4367 Rclds**

**Facility ID # Area 5 Pedestrian Signals**

**Author: Vaish, B**

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
17	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
18	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
19	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
20	Palos Verdes Dr. West & Hawthorne Blvd.	04.29A - Push Button Height	Height of pedestrian signal push button exceeds 48" max..	4.2.5; 4.2.6	308.2.1; Fig. 308.2.1;	1117B.5 .9		49" AFF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
21	Palos Verdes Dr. West & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	8.9%.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
22	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
23	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
24	Palos Verdes Dr. West & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
25	Palos Verdes Dr. West & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	7.3%.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
26	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
27	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment  
 Compliance Report**



Reporting: 112 of 4367 Rclds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
28	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
29	Palos Verdes Dr. West & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	3.5%.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
30	Palos Verdes Dr. West & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
31	Palos Verdes Dr. West & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
32	Palos Verdes Dr. West & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
33	Vallon Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



**Reporting: 112 of 4367 Rcds**

**Facility ID # Area 5 Pedestrian Signals**

**Author: Vaish, B**

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
34	Vallon Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
35	Vallon Dr. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G-R306.3.1; R405.4	Greater than 5 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
36	Vallon Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	3.5% CS & 7.1% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
37	Vallon Dr. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G-R306.3.1; R405.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
38	Vallon Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rclds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
39	Vallon Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
40	Vallon Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	7% CS. & 10.2% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
41	Vallon Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
42	Vallon Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
43	Vallon Dr. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G-R306.3.1; R405.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))





*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
44	Vallon Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	3.8% CS & 6.4% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
45	Vallon Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
46	Vallon Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
47	Vallon Dr. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
48	Vallon Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	2.3% CS % 12.4% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**  
**Facility ID # Area 5 Pedestrian Signals**



**Reporting: 112 of 4367 Rcds**

**Author: Vaish, B**

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
49	Dupree Dr. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-	Pedestrian signal is not provided.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
50	Dupree Dr. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-		PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
51	Dupree Dr. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
52	Dupree Dr. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
53	Dupree Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
54	Dupree Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
55	Dupree Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	6% CS & 8.3% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
56	Dupree Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	6.1% CS & 7.6% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
57	Dupree Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
58	Dupree Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
59	Dupree Dr. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rclds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
60	Dupree Dr. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
61	Dupree Dr. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
62	Dupree Dr. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
63	Dupree Dr. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
64	Dupree Dr. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	7.9% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
65	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	2.2% CS & 5.9% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
66	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
67	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
68	Crest Rd. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-	Path of travel to pedestrian signal device is not provided.	PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
69	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	2.2% CS & 11.8% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



**Reporting: 112 of 4367 Rclds**

**Facility ID # Area 5 Pedestrian Signals**

**Author: Vaish, B**

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
70	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
71	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
72	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
73	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
74	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
75	Crest Rd. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G-R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**  
**Facility ID # Area 5 Pedestrian Signals**



Reporting: 112 of 4367 Rcds

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
76	Crest Rd. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-		PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
77	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
78	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
79	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
80	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3;	1118B.4 item 1	2005 PROWA G-R306.2.1	5.2% CS & 4.2% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rclds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
81	Crest Rd. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G-R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
82	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
83	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
84	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
85	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	13.4% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))





*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**  
**Facility ID # Area 5 Pedestrian Signals**



Reporting: 112 of 4367 Rcds

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
86	Crest Rd. & Hawthorne Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
87	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
88	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
89	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	5.9% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
90	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rclds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
91	Crest Rd. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-	Path of travel to pedestrian signal device is not provided.	PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
92	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
93	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
94	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
95	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	3.1% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
96	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
97	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
98	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
99	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2. 1	3.7% CS & 4.5% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
100	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3. 3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
101	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
102	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



Reporting: 112 of 4367 Rcds

Facility ID # Area 5 Pedestrian Signals

Author: Vaish, B

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
103	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	3.1% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
104	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
105	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
106	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
107	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	5.9% CS & 3.8% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



*City of Rancho Palos Verdes*  
**Rancho Palos Verdes ADA Assessment**  
**Compliance Report**



**Reporting: 112 of 4367 Rcds**

**Facility ID # Area 5 Pedestrian Signals**

**Author: Vaish, B**

**Group 04 - Curb Ramps**

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
108	Crest Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	2.1% CS & 8.1% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
109	Crest Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
110	Crest Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
111	Crest Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
112	Palos Verdes Dr. West & Hawthorne Blvd.	04.29A - Push Button Height	Height of pedestrian signal push button exceeds 48" max..	4.2.5; 4.2.6	308.2.1; Fig. 308.2.1;	1117B.5 .9	-	49" high.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))

**Number of Key Notes for Group 04 - Curb Ramps: 112**



Reporting: 112 of 4367 Rcds

*City of Rancho Palos Verdes*  
Rancho Palos Verdes ADA Assessment  
**Compliance Report**  
Facility ID # Area 5 Pedestrian Signals



Author: Vaish, B

---

---

**Number of Key Notes for Facility Area 5 Pedestrian Signals: 112**

---

**Total Number of Key Notes for All Groups: 112**