



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report

Reporting: 19 of 4367 Rcds



Facility ID # Area 3 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991	2004	2007	2005	Existing PROWA Condition	Use	Severity	Location Type
				ADAAG	ADAAG	CBC	PROWA				
1	Blackhorse Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G-R306.2. 1	8.4% CS & 8.6% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
2	Blackhorse Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
3	Blackhorse Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
4	Blackhorse Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3. 3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
5	Blackhorse Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G-R306.2. 1	4.3% & 5.6% CS & 12.1% & 13.1% RS	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 3 Pedestrian Signals



Reporting: 19 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
6	Blackhorse Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3. 3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
7	Blackhorse Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
8	Blackhorse Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
9	Blackhorse Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4 Fig. 305.3	305.3; item 1	1118B.4	2005 PROWA G- R306.2. 1	11.3% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
10	Blackhorse Rd. & Hawthorne Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-	Path of travel to the pedestrian signal device is not provided.	PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
11	Blackhorse Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report

Reporting: 19 of 4367 Rcds



Facility ID # Area 3 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991	2004	2007	Existing PROWA Condition	Use	Severity	Location Type	
				ADAAG	ADAAG	CBC					
12	Blackhorse Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))	
13	Blackhorse Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3. 3	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))	
14	Blackhorse Rd. & Hawthorne Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))	
15	Blackhorse Rd. & Hawthorne Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))	
16	Blackhorse Rd. & Hawthorne Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3. 3	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))	
17	Blackhorse Rd. & Hawthorne Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2. 1	5.2% CS & 19.3% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
 Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 3 Pedestrian Signals



Reporting: 19 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991	2004	2007	Existing PROWA Condition	Use	Severity	Location Type	
				ADAAG	ADAAG	CBC					
18	Blackhorse Rd. & Hawthorne Blvd.	04.26C - Pedestrian Signal Device - Spacing	Pedestrian signal devices at a crossing are spaced less than 10' apart.	-	-	-	2005 PROWA G- R306.2. 1.1	Mounted on same pole.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
19	Blackhorse Rd. & Hawthorne Blvd.	04.29A - Push Button Height	Height of pedestrian signal push button exceeds 48" max..	4.2.5; 4.2.6	308.2.1; 1117B.5 - Fig. .9 308.2.1; 308.3.1; Fig. 308.3.1			49 1/4" high.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))

Number of Key Notes for Group 04 - Curb Ramps: 19

Number of Key Notes for Facility Area 3 Pedestrian Signals: 19

Total Number of Key Notes for All Groups: 19